

## **SPECIFICATIONS – EVT0001728**

### **BUILDING SURGE PROTECTIVE DEVICES**

Install Type 2 Panel mounted Surge Protective Devices at 2650 E. Circle Drive South, Topeka, Kansas, and also at 417 S. W. Jackson, Topeka, Kansas, and replace a defective in-panel Surge Protector at 401 S. W. Topeka Blvd., Topeka, Kansas.

1. Surge Protection devices at 2650 E. Circle Drive South and 417 Jackson are to be mounted at the electrical service entrance to the building. These units need to be Type 2 Panel mounted Surge Protective Devices 120/208 VAC 3-phase WYE.
2. At 401 S.W. Topeka Blvd. an in-panel Eaton/Cutler-Hammer 160KA Surge Protector needs to be replaced due to a fault warning. The replacement unit can be of another make and model as long as it meets the design specs of the original. The replacement does not need to be mounted in-panel, as it can be mounted next to the branch panel.
3. All work must be performed after normal business hours. This would be after 5:00 PM on weekdays, and anytime Saturday or Sunday. The actual work must be scheduled at least one week in advance with KDOL.
4. Bidders must be of known reputation and shall have sufficient qualified personnel and equipment to perform the specified services. Bidders shall submit with their quotation, evidence of their qualifications.
5. Bidder shall furnish as part of the bid, the name and contact information of the person who will have responsibility for planning and directing the installs and replacement.
6. Bidders must provide as part of the bid, the make and model of Surge Protective Devices they plan to install along with the technical specifications.
7. Due to funding of the project, the bidder must provide an individual price for the labor and an individual price for the materials for each building. Overhead and profit charges should be included within these costs for labor and materials. The bid will be awarded for all three buildings as one project.
8. Bidders shall provide a completed Event Details. Bidder shall also provide pricing and other information on the attached Bid Form.
9. A pre-bid conference and walkthrough will be held on September 26<sup>th</sup>, at 10:00 AM, at the Eastman Building main entrance, at 2650 E. Circle Drive South, Topeka, Kansas.
10. For those who cannot make the pre-bid conference, access to the building and inspections of the install areas can be provided by contacting Frank Scheetz at 785-296-5094 or at 785-817-5028 or by e-mail at [frank.scheetz@dol.ks.gov](mailto:frank.scheetz@dol.ks.gov).